



कार्यालय नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर।

पत्रांक:- 256/D/SWA/NSA

दिनांक:- 21/06/2021

प्रमाण पत्र

प्रमाणित किया जाता है की सफाई एवं खाद्य निरीक्षक/केमिस्ट स्वास्थ्य विभाग द्वारा दिनांक 15.06.2021 को सर पदमपत सिंहानिया एजुकेशन सेन्टर, कमला नगर कानपुर नगर का निरीक्षण किया गया तथा पानी का सैम्पल लिया गया जिसमें पेयजल की गुणवत्ता पेययोग्य एवं विद्यालय में सेनेटरी एवं हाइजेनिक स्थितियां हैल्थ मैनुअल के अनुरूप सही पायी गयी है।

नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर
ALKA SINGH
(Chemist)
Nagar Nigam Kanpur

Bhawna Gupta
Principal
Sir Padampat Singhania Education Centre
Kamla Nagar, Kanpur-208005

KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY KANPUR NAGAR NIGAM

Chemical water analysis report for the Sir Padampat Singhania Education Centre
Submergeable Kamla Nagar
Kanpur

Sample taken from — — — — —
Date of sample Drawn — — — — — 15/06/2021
Date of analysis — — — — — 15/06/2021
Physical Character — — — — — Transparent
P. H. Value — — — — — 7.9
Free Ammonia Parts per 1000000 — — — — — Nil
Alouninoid Ammonia Part per 1000000 — — — — — Nil
Oxygen absorbed from pot. Permagnate
in three hours at 37° C — — — — — 0.0
Chloride Part per 1000000 — — — — — 25.0
Nitrates Parts per 1000000 — — — — — Nil
Nitrates Parts per 1000000 — — — — — Nil
Total solid part per 100000 — — — — — 370.0
Fixed solid Parts per 1000000 — — — — — 310.0
Volatils solid Parts per 100000 — — — — — 60.0
Appearance on ignition — — — — — No Charring
Total hardness Parts per 1000000 — — — — — 190.0
Permanent hardness Parts per 1000000 — — — — — 154.0
Temporary hardness Parts per 1000000 — — — — — 36.0

Remarks :

Potable

No 234/2021 dated 21/06/2021

Copy forwarded for favour or information to

Sir Padampat Singhania
Education Centre Kamla Nagar
Kanpur

M.S.A. Nagar Aligarh Kanpur

Nagar Swasthya Adhikari
Nagar Nigam Kanpur

नगर निगम कानपुर

ALKA SINGH
(Chemist)

Nagar Nigam Kanpur

Bharana Gupta
Principal

Sir Padampat Singhania Education Centre
Kamla Nagar, Kanpur-208005



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from Sir Padampat Singhania Education Centre

Name & designation of the person collecting samples..... Alka Singh - Chemist (K.N.N.) Kamlu Nagar Kanpur

Date of on	Source of sample	Colony count on Agar Agar per M. L. of water		Presumptive Coliform count				Probable on of coliform organism in 100 CC of original water	Free Residual Chlorine part per Million	REMARKS
		at 37.c in 48 hours	at room temp- rature in 72 hours	Quantity of water put in each tube No of tubes put up	50ML. 1	10 ML. 5	1 ML 5			
2021	Submersible	Zero	Zero	—	NIL	NIL	NIL	Zero	2.5	'Excellent'

Information Forwarded to

- (1) Sir Padampat Singhania Education Centre
Kamlu Nagar Kanpur Nagar
- (2) N.S.A. Nagar Nigam Kanpur.

Bhawna Gupta
Principal

Sir Padampat Singhania Education Centre
Kamlu Nagar, Kanpur-208005

Nagar Swasthya Adhikari

नगर स्वास्थ्य अधिकारी

कानपुर नगर निगम

ALKA SINGH

(Chemist)